

EVO XL Water Heater Placement Options



EVO XL Model: _____

1 2 3 4 5 6 7 8

System Connections

Tank Location:	L	R	New	Existing	} Distance (TEF): _____		} Pipe Diameter: _____
			CWIS:	No	Yes	} Building Recirc Line	Laundry w/Recirc
						No Building Recirc Line	Laundry wo /Recirc
Gas Connections:	L	R	Gas Type:		NG	LP	
Hamilton Supplied Gas Regulator:	Y	N	Incoming Gas Pressure: _____		WC	PSI	
Condensate:	Y	N	Regulator type:		Vented	Ventless	
Electrical Panel:	Y	N	Transformer Ordered:		Y	N	Voltage: _____
			Venting Material:		Adaper Centro Therm	PVC/CPVC	
BMS Ordered:	Y	N	Protocol: _____				
Altitude: At what elevation will this system be installed?			_____ft.				
High Limit Required:	Standard 198°F (Field Adjustable Upto 210°F)						
<i>*NOTE: If protonode is selected, Protocol must be completed.</i>							
Maximum Operating Temperature: _____	City Water Pressure:(If Expansion Tank Ordered) _____						
Reports Required:	ASME (LIT CG500)		CSD-1 (LIT CSD1U1)				

Note: If water temperature setpoint will be over 120°F, a water analysis is required.

Desired temperature exceeds 160°F;

Additional Notes and Special Parameters :

Distributor: _____ **Project:** _____ **Purchase Order #:** _____

Signed: _____ **Date:** _____ **Quote Builder #:** _____